

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0328:154 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Potter, 2081 Craig Road, St. Louis MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Model PFC-3002 and PFC-3005 fire alarm control units. Non-coded; automatic, manual, local, waterflow and sprinkler supervisory service. System components:

DM-102S	Supervisory Board (2 Zone)
RM-104	Quad Relay Board
AM-108	Annunciator Driver Board
WM-101	Walk Test Board
DM-102	Detection (2 Zone)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation Manual for details.

XLF: 7165-1477:102

09-11-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager